


- Order Limits
- Potential Development Area for Solar
- 15 m buffer of Ancient Woodland Inventory
- 15 m buffer of SSSI
- 15 m buffer of Local Wildlife Site
- 5 m buffer of Solar Field edges
- 10 m buffer of Bridleway
- 5 m buffer of Public Rights of Way
- 30.6m buffer of Transmission OHL
- 3.6 m buffer of 132 kV OHL
- 11 m buffer 33 kV OHL
- 8 m buffer of 11 kV OHL
- 10m buffer of Non-TVIDB maintained watercourse
- 10m buffer of TVIDB maintained watercourse
- 10m buffer of TVIDB EA Board maintained watercourse
- 10 m buffer of Waterbodies
- Flood Areas greater than 1 m (EA)
- Flood Areas gtr 0.7m CC
- Landscape Scoping Design Review**
- Amber
- Red
- 100 m buffer of Residential Receptors (String Inverter)
- Geophysics Constraints**
- Constraint to factor in
- Recommend area removal



Constraints
GNR Solar Farm